

These tables list all of the drinking water contaminants that were **detected** during the most recent sampling for each constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked and explained below.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
<i>E. coli</i>	(in the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive, or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper	No. of samples collected	90 th percentile level detected	Range of Detections	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb) 08/2023	5	1	0 - 1	None	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm) 08/2023	5	0.247	0.003 - 0.440	None	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. IVCS - Crescent Mills is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact IVCS - Crescent Mills at 530-284-7224. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	06/26/18 12/10/19	Well 01 - 10.3 Spring 01 - 10.3		None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	06/26/18 12/10/19	Well 01 - 100 Spring 01 - 115		None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Nitrate (ppm)	04/03/25	0.07	ND - 0.14	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Chromium (hexavalent) (ppb)	12/05/24	0.08	ND - 0.16	10	0.02	Erosion of natural deposits; transformation of naturally occurring trivalent chromium to hexavalent chromium by natural processes and human activities such as discharges from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities.
Total Trihalomethanes - TTHM (ppb)	08/07/25	3.5		80	N/A	Byproduct of drinking water disinfection

TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Iron (ppb)	2025 2023	Well 1 - 600* Spring 01 - 4716*	ND - 1200* 501 - 8930*	300	None	Leaching from natural deposits; industrial wastes
Manganese (ppb)	2025 12/10/19	Well 01 - 129* Spring 01 - 121*	0.69 - 257*	50	None	Leaching from natural deposits
Sulfate (ppm)	10/13/20 12/10/19	Well 01 - 7.6 Spring 01 - 16.1		500	None	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	10/13/20 12/10/19	Well 01 - 151 Spring 01 - 168		1000	None	Runoff/leaching from natural deposits
Specific Conductance (µS/cm)	10/13/20 12/10/19	Well 01 - 242 Spring 01 - 269		1600	None	Substances that form ions when in water; seawater influence
Color (units)	11/07/17	10		15	None	Naturally occurring organic materials
Turbidity (units)	11/07/17	6.2*		5	None	Soil runoff

*There are no PHGs, MCLGs, or mandatory standard health effects language for these constituents because secondary MCLs are set on the basis of aesthetics.